

HEATING PROCEDURE CERTIFICATE FOR SUBFLOOR WITH UNDERFLOOR HEATING

TO BE COMPLETED BY THE INVESTOR (CONSTRUCTION SUPERVISION INSPECTOR)
– concerns one room: (e.g. living room, kitchen, other...)

Place of installation:

a) flat

b) house

c) other

Address:

DAY	SET AT TEMP.	NOTES	DATE	SIGNED
1.	20°C – 68°F			
2.	30°C – 86°F			
3.	40°C – 104°F			
4.	50°C – 122°F			
5.	50°C – 122°F			
6.	50°C – 122°F			
7.	50°C – 122°F			
8.	50°C – 122°F			
9.	50°C – 122°F			
10.	50°C – 122°F <small>(or maximum system operating temperature)</small>			
11.	50°C – 122°F			
12.	50°C – 122°F			
13.	50°C – 122°F			
14.	50°C – 122°F			
15.	50°C – 122°F			
16.	40°C – 104°F			
17.	30°C – 86°F			
18.	20°C – 68°F			
19.	Turn off heating			
20.				
21.				
22.				
23.				
24.	20°C – 68°F			
25.	30°C – 86°F			
26.	40°C – 104°F			
27.	50°C – 122°F			
28.	40°C – 104°F			
29.	30°C – 86°F			
30.	20°C – 68°F			

.....
Date and signature of fitter.
Stamp of company responsible for assembly.

.....
Date and legible signature of Investor
(Supervising Inspector)